



Computer and Makerspace Lab Evaluation Checklist

Basic Inspection Information

INSPECTOR DETAILS

INSPECTOR CONTACT

INSPECTION DETAILS

Basic Space Information

SPACE

BUILDING

AREAS

PRIMARY MEMBERS

Space - Custom Fields

DEPARTMENT

Inspection Responses

Fire/Life Safety

<p>Good housekeeping practices are followed Good housekeeping practices are followed in the laboratory.</p>	No Response
<p>Lab doors are kept closed Lab doors are kept closed to provide a fire and smoke barrier.</p>	No Response
<p>Exits and walkways must be kept clear Exits and walkways must be kept free of obstructions and tripping hazards.</p>	No Response

Ceiling tiles are in place and undamaged Ceiling tiles are in place and undamaged	No Response
Storage of combustibles, e.g., cardboard boxes and paper, are kept to a minimum Combustibles are not stored within 24" of the ceiling in non-sprinklered buildings or within 18" of the sprinkler head drop distance from the ceiling.	No Response
Class ABC fire extinguisher (min 10 lbs.) is present in the laboratory or within 75 ft	No Response
Fire extinguisher is unobstructed	No Response
Fire extinguisher has a current inspection and is in working order	No Response
Comments/Notes Comments/Notes	No Response

Electrical Safety

Permanent use of extension cords Permanent use of extension cords has been eliminated. No multi-plug adapters are used or power strips plugged into other power strips.	No Response
Electrical cords are appropriately used Electrical cords are appropriately used (i.e. none are routed above the ceiling tiles or across the floor where they could be a tripping hazard).	No Response
Electrical cords are in good condition Electrical cords are in good condition. (i.e. none have exposed wiring or cracked, brittle, or frayed insulation).	No Response
Clear access to electrical breaker panel There is 36 inches of clearance around electrical breaker panel	No Response
Comments/Notes Comments/Notes	No Response

Comments

Comments	No Response
Comments	No Response
Signature	No Response